

Date	D ₆ on	D ₆ off	R	Y	B	KUH	Battery Voltage	Engine Hour	Diesel open	Diesel Close	Diesel Consumption	Unaid Consumed	Diesel filled	Diesel Produced	Remarks
1/11/2021						104429	27.3	1917.0	76.7	52.7	24.7	800			
2/11/2021						104435	27.3	1917.1	52.7			06			
3/11/2021						104492	27.3	1918.4	52.7	48.7	04.7	57			
4/11/2021						104492	27.3	1918.4	48.7	48.7					
5/11/2021						104512	27.2	1919.3	49.1	44.7	04.7	20			
6/11/2021						104512	27.3	1919.3	49.1	88.7			130Ltr		
7/11/2021						104512	27.2	1919.3	88.1	88.7					
8/11/2021						104519	27.2	1919.5	88.1	86.7	02.7	07			
9/11/2021						104519	27.8	1919.5	86.7	86.7					
10/11/2021						104519	27.3	1919.5	86.7	86.7					
11/11/2021						104519	27.2	1919.5	86.7	86.7					
12/11/2021						104603	27.3	1920.4	86.7	74.7	18.7	84	70Ltr		
13/11/2021						104603	27.2	1920.4	88.7	88.7					
14/11/2021						104603	27.2	1920.4	88.7	88.7					
15/11/2021						104603	27.3	1920.4	82.7	82.7					
16/11/2021						104639	26.2	1920.8	82.7	80.7	02.7	26			
17/11/2021						104637	27.2	1920.9	80.7	79.7	01.7	08			
18/11/2021						104637	27.2	1920.9	79.7	79.7					
19/11/2021						104646	27.2	1921.2	79.7	84.7	14.7	09	130Ltr		
20/11/2021						104646	27.2	1921.2	84.7	84.7					
21/11/2021						104646	27.2	1921.2	84.7	84.7					
22/11/2021						104646	27.2	1921.2	84.7	84.7					
23/11/2021						104646	27.2	1921.2	84.7	84.7					
24/11/2021						104646	27.2	1921.2	84.7	84.7					
25/11/2021						104646	27.2	1921.2	84.7	84.7					
26/11/2021						104646	27.2	1921.2	84.7	84.7					
27/11/2021						104646	27.2	1921.2	84.7	84.7					
28/11/2021						104646	27.2	1921.2	84.7	84.7					
29/11/2021						104646	27.2	1921.2	84.7	84.7					
30/11/2021						104646	27.2	1921.2	84.7	84.7					

9350 / 800Ltr
19/11/21
Korli
21/11/21
800Ltr

9446 / 800Ltr
06/11/2021
Obilal

9355 / 800Ltr
30/11/21
B

FORM - G

See sub-rule (2) of rule-5.

Returns showing the Particulars of Electricity Generation, Auxiliary consumption, Captive Consumption, 3rd party Sales through Licensee or dedicated

Transmission line by a non Licensee & details of Electricity Tax Paid for the month of **SEPTEMBER -2021**

GENERATOR DETAILS

SL NO	RR NO	CAPACITY	MAKE	SLNO	FUEL USED	APPROVAL REFERENCE
1	BW-2225	250 KVA	KIRLOSKAR	14C182879	HSD	ACEI/(BS)/DCEI(BW)/AEI
2						327-30/2014-15
3						

SL NO	ENERGY METER READING			UNIT RATED	CONSUMPTION (UNIT)		SALE OF ELECTRICITY(UNIT)		TAX PAID DEATILS			TOTAL	REMARKS	
	OPENING READING CONSTANT	CLOSING READING	ENERGY METER		AUXILIARY CONSUMPTION	CAPTIVE CONSUMPTION	THROUGH GRID	THROUGH DEDICATED TRANSMISSION LINE	AUXILIARY	SOLD	CAPTIVE			THROUGH GRID
1	121687	1	122727	1040										
2														
3														
4														

NOTE 1 : Incase of third party sale the details of sale shall be furnished long with PPA agreement & OM copy from the concerned BESCOM

NOTE 2 : Supply & Consumption as provisionally determined by the inspecting office


 SHIVAKUMAR ENGINEER

MAINTENANCE ENGINEER
BCS GIMS & HOSPITAL
Kengeri, Bangalore-560 060

Stock Register

Unit

Article	MONTH & DATE	Particulars	Opening Stock	Arrivals Receipts	Total	Issues Sales	Closing Stock	Remarks
	25/11/21	36W Led Light		71	3rd Floor			
		"		72	Teacher's hall			Comp
		"		73	"			Main hall
		"		74	"			Ball
		"		75	"			
		"		76	"			
		"		77	"			
		"		78	"			
		"		79	"			
		"		80	"			
	15/12/21	1/2 LED 36WATT	3m	81				
		pond pump	4m	82				
		150Watt 2000V	5m	83				
		Team Cartery	2m	84				
	15/12/21	1/4 LED Lighting	15	85				
		1/4 LED Light	15	86				
		1/4 LED Light	15	87				
		1/4 LED Light	15	88				
	23/01/22	1/4 SIGHT LIGHT	19	89				
		1/4 SIGHT LIGHT	19	90				
	24/03/22	1/4 SIGHT LIGHT	91	91				
		1/4 SIGHT LIGHT	91	92				
	09/04/21	1/2 LED Light	93	93				
		1/2 LED Light	93	94				
		1/2 LED Light	93	95				

Stock Register

Unit

Article	MONTH & DATE	Particulars	Opening Stock	Arrivals Receipts	Total	Issues Sales	Closing Stock	Remarks
	01/02/22	1/2 LED Light	96	96				
		1/2 LED Light	97	97				
		1/2 LED Light	98	98				
		1/2 LED Light	99	99				
		1/2 LED Light	100	100				
	19/05/22	2/5 LED Light	101	101				
		2/5 LED Light	102	102				
	30/05/22	2/5 LED Light	103	103				
		36WATT 200V	104	104				
	09/06/22	2/5 LED Light	105	105				
		36WATT 200V	106	106				
	01/06/22	1/4 SIGHT LIGHT	107	107				
		1/4 SIGHT LIGHT	108	108				
	25/08/21	1/2 SIGHT LED	109	109				
	26/08/21	1/2 SIGHT LED	110	110				
	26/08/21	1/2 SIGHT LED	111	111				
	26/08/21	1/2 SIGHT LED	112	112				
	26/08/21	1/2 SIGHT LED	113	113				
	26/08/21	1/2 SIGHT LED	114	114				
	26/08/21	1/2 SIGHT LED	115	115				
	26/08/21	1/2 SIGHT LED	116	116				
	26/08/21	1/2 SIGHT LED	117	117				
	26/08/21	1/2 SIGHT LED	118	118				
	26/08/21	1/2 SIGHT LED	119	119				
	26/08/21	1/2 SIGHT LED	120	120				
	26/08/21	1/2 SIGHT LED	121	121				
	26/08/21	1/2 SIGHT LED	122	122				
	26/08/21	1/2 SIGHT LED	123	123				
	26/08/21	1/2 SIGHT LED	124	124				
	26/08/21	1/2 SIGHT LED	125	125				
	26/08/21	1/2 SIGHT LED	126	126				
	26/08/21	1/2 SIGHT LED	127	127				
	26/08/21	1/2 SIGHT LED	128	128				
	26/08/21	1/2 SIGHT LED	129	129				
	26/08/21	1/2 SIGHT LED	130	130				
	26/08/21	1/2 SIGHT LED	131	131				
	26/08/21	1/2 SIGHT LED	132	132				
	26/08/21	1/2 SIGHT LED	133	133				
	26/08/21	1/2 SIGHT LED	134	134				
	26/08/21	1/2 SIGHT LED	135	135				
	26/08/21	1/2 SIGHT LED	136	136				
	26/08/21	1/2 SIGHT LED	137	137				
	26/08/21	1/2 SIGHT LED	138	138				
	26/08/21	1/2 SIGHT LED	139	139				
	26/08/21	1/2 SIGHT LED	140	140				
	26/08/21	1/2 SIGHT LED	141	141				
	26/08/21	1/2 SIGHT LED	142	142				
	26/08/21	1/2 SIGHT LED	143	143				
	26/08/21	1/2 SIGHT LED	144	144				

Stock Register

Unit

Article	MONTH & DATE	Particulars	Opening Stock	Arrivals Receipts	Total	Issues Sales	Closing Stock	Remarks
	16/05/22	1kg new mounting fan	145	AHS Office		None		Priority
		Reddy's Fan	146	" "		Completed		
	25/08/20	9/2 LED Light	147	TSD Office				work
			148	" "				Priority
			149	Microtek bin				
			150	office chairs				
			151	" "				
			152	" "				
	24/05/22	9/2 LED Light	153	College				work
			154	board room				Completed
			155	" "				
			156	" "				
			157	" "				
			158	" "				
			159	" "				
			160	" "				
			161	" "				
			162	" "				
			163	" "				
			164	" "				
			165	" "				
			166	" "				
			167	" "				
			168	" "				
			169	" "				
			170	" "				
			171	" "				
			172	" "				
			173	" "				
			174	" "				
	22/04/22	9/2 LED Light	175	GNID Lab				Priority

Stock Register

Unit

Article	MONTH & DATE	Particulars	Opening Stock	Arrivals Receipts	Total	Issues Sales	Closing Stock	Remarks
	09/09/22	9/2 LED Light	176	GNID Lab				Priority
			177	" "				
			178	" "				
	05/10/22	9/2 LED Light	179	Microbiology office				Priority
			180	GNID				
	02/09/21	18 watt ground sand light	181	" "				
			182	" "				
			183	" "				
			184	" "				
			185	" "				
			186	" "				
			187	" "				
			188	" "				
			189	" "				
			190	" "				
			191	" "				
			192	" "				
			193	" "				
			194	" "				
			195	" "				
			196	" "				
			197	" "				
			198	" "				
			199	" "				
			200	" "				
			201	" "				
	23/09/22	Principal's office	202	Principal's office				Priority
		9/2 LED Light	203	" "				
			204	" "				
			205	" "				



ADICHUNCHANAGIRI SHIKSHANA TRUST (R.)
BSGLOBAL INSTITUTE OF MEDICAL SCIENCES

(Affiliated to Rajiv Gandhi University of Health Sciences, Bangalore)
No. 67, BGS Health & Education City, Uttarahalli Road, Kengeri,
Bangalore- 560060, Karnataka

Date: 30-09-2022

TO,

The Dean cum Principal,

BGS GIMS,

Bangalore.

Respected Sir,

Sub: Repair at BGS GIMS Teaching & Non Teaching Quarters .

With reference to the above subject, I Would likes to bring your kind notice regarding Motor starter repair work at BGS GIMS Quarters.

I request your kind self to consider this matter on priority and do the needful at the earliest

Thanking

Yours Faithfully

[Signature]
30/09/2022
[Asst Warden]

[Signature]
Dean cum Principal
BGS Global Institute of Medical Sciences
67, Uttarahalli Road, Kengeri,
Bangaluru - 560 060.

30/09/2022



ADICHUNCHANAGIRI SHIKSHANA TRUST (R.)
BGS GLOBAL INSTITUTE OF MEDICAL SCIENCES

(Affiliated to Rajiv Gandhi University of Health Sciences, Bangalore)
No. 67, BGS Health & Education City, Uttarahalli Road, Kengeri,
Bangalore- 560060, Karnataka

Date: 26-09-2022

TO,

The Dean cum Principal,

BGS GIMS,

Bangalore.

Respected Sir,

Sub: Requirements for BGS GIMS boy's hostel,AHS & GINS boys Hostel
,Teaching & Non Teaching Quarters .

With reference to the above subject, I Would likes to bring your kind notice
regarding requirements for BGS GIMS Boys Hostel,AHS & GINS Boys
Hostel,Teaching & Non Teaching Quarters.

1.LED Tubelight - 20 nos .

I request your kind self to consider this matter on priority and do the
needful at the earliest

Thanking

Yours Faithfully

WARDEN

BGS Global Institute of Medical Sciences
67, Uttarahalli Road
Kengeri, Bangalore - 560 060.

Dean cum Principal
BGS Global Institute of Medical Science:
67, Uttarahalli Road, Kengeri,
Bengaluru - 560 060.



ADICHUNCHANAGIRI SHIKSHANA TRUST (R.)
BGS GLOBAL INSTITUTE OF MEDICAL SCIENCES

(Affiliated to Rajiv Gandhi University of Health Sciences, Bangalore)
No. 67, BGS Health & Education City, Uttarahalli Road, Kengeri,
Bangalore- 560060, Karnataka

Date: 27-07-2022

TO,
The Dean cum Principal,
BGS GIMS,
Bangalore.

Respected Sir,

Sub: Requirement for BGS Allied Health Sciences & BGS GIMS boy's hostel
,Teaching & Non Teaching Quarters .

With reference to the above subject, I Would like to bring your kind notice
regarding electrical items requirement for BGS Allied Health Science & BGS
GIMS boys Hostel,Teaching & Non Teaching Quarters.

1. Ceiling fan - 10 nos.
2. LED Tubelight - 20nos.
3. 15 Amps Switches - 20 nos.(01 Box).
4. Mirrors - 03 nos.

I request your kind self to consider this matter on priority and do the needful at
the earliest

Thanking

Yours Faithfully

WARDEN

BGS Global Institute of Medical Sciences
67, Uttarahalli Road
Kengeri, Bangalore - 560 060.

Dean cum Principal
BGS Global Institute of Medical Science:
67, Uttarahalli Road, Kengeri,
Bangalore - 560 060.

28/7/22

882

5

12/10/22

2 in Sri Adichunchanagiri Shikshana Trust
BGS GLOBAL INSTITUTE OF MEDICAL SCIENCE
#67, UTTARAHALLI MAIN ROAD, KENGERI, BANGALOR-60

DATE 10 /10/2022
INDENT NO-

TO,
M/S _____
BANGALORE

Please Supply the following materials through our Staff/ Direct Delivery to Store
Hospital NICU REST ROOM purpose

SL NO	ITEM	QTY	REMARKS
01			
02	Flush tank	03	"
03	Angler cock 2 in 1	02	"
04	Connictiton pipe 1 meter	03	
05	health focet (water tec)	02	"
06	CP nipple 1/2 x 2 inch	04	"
07	Teflon tape	04	"
08	Angler cock	02	"

2nd copy

Sulim Kumar
ENGINEER 10/10/2022

[Signature]
ADMINISTRATOR

ADICHUNCHANAGIRI SHIKSHANA TRUST (R.)
BGS GLOBAL INSTITUTE OF MEDICAL SCIENCES
(Affiliated to Rajiv Gandhi University of Health Sciences)

Sri Adichunchanagiri Shikshana Trust
BGS GLOBAL INSTITUTE OF MEDICAL SCIENCE
#67, UTTARAHALLI MAIN ROAD, KENGERI, BANGALOR-60

DATE 17 /08/2021
INDENT NO-

TO,
M/S _____
BANGALORE

Please Supply the following materials through our Staff/ Direct Delivery to Store
Hospital 1th to 5th floor ward & corridor PURPOSE

SL NO	ITEM	QTY	REMARKS
01	3 model plate & box PVC	03	
02	15 ams switch	10	
03	15 ams socket	10	
04	Tape	04	
05	9/9 led fitting	20	
06	Fan nab switch type	35	
17	Fan nab socket type	05	
08	5 ams switch	10	
09	5 ams socket	10	
10	Celing fan brown & white	02	
11	Fan copocitar	10	
12	6 model box & plate PVC	01	
13	TUBE LIGHT 20W	05	

Shiva Kumar
ENGINEER

MAINTENANCE ENGINEER
BGS GIMS & Hospital
Kengeri, Bengaluru

[Signature]
ADMINISTRATOR

[Signature] 17/8/21

INDEX

NAME

STD.

DIV.

ROLL NO.

Sl. No.

Date

Title

Page No.

Teacher's
Sign / Remarks

IT MAINTENANCE REGISTER



GPS Map Camera



al Institute
Sciences
Google

Bengaluru, Karnataka, India


Bgs Global Institute Bgs Global Institute Of Medical
Sciences, Kodipalya, Bengaluru, Karnataka 560060,
India

Lat 12.900046°

Long 77.497017°

07/10/22 01:23 PM GMT +05:30

Article	Opening Stock	Arrivals Receipts	Total	Issues Sales	Closing Stock	Remarks
MONTH & DATE						
Particulars	250				200	
To: PRINCIPAL (ACER)				01		Kejriwal
To: PRINCIPAL PA (ACER)				01		
To: Conference hall (CHP)				01		
(ALL IN ONE)						
To: Establishment Section (ACER)				01		Apich
To: Establishment Section (ACER)				01		Apich
To: Registrar (CHP)				01		Abhinav
(ALL IN ONE)						
To: Registrar (CHP)				01		Abhinav
(ALL IN ONE)						
To: Accounts (ACER)				01		} 27/8/20 (Arjun)
To: Accounts Office (ACER)				01		



Bengaluru, Karnataka, India
 WF2W+2JM, Kodipalya, Bengaluru, Karnataka
 560060, India
 Lat 12.900006°
 Long 77.496804°
 07/10/22 12:49 PM GMT +05:30

IT STOCK BOOK



GPS Map Camera



Global Institute
of Sciences
Google

Bengaluru, Karnataka, India

WF2W+2JM, Kodipalya, Bengaluru, Karnataka

560060, India

Lat 12.900128°

Long 77.49681°

07/10/22 12:48 PM GMT +05:30


COMPUTER HOSPITAL
MAYUR [HOSPITAL] Stock Register

MAYUR

MONTH & DATE	Particulars	Opening Stock	Arrivals Receipts	Total	Issues Sales	Closing Stock	Remarks	MONTH & DATE	Particulars
	TO: PRINCIPAL CHAMBER (ACER)				01 (ONE)		1/11 (Friday)		TO: General Medicine (ACER)
	TO: Hqs office (HP All in one)				01 (ONE)		1/11 (Friday)		TO: ICU (ACER)
	TO: M.S. office Computer operator (ACER)				02 (Two)		1/11 (Friday)		TO: NICU PICU (ACER)
	TO: A.O. office (ACER)				01		1/11 (Friday)		TO: optomol dept. (ACER)
	TO: Billing section (ACER)				08		1/11 (Friday)		TO: optomol library (ACER)
	TO: Casualty (ACER)				09		1/11 (Friday)		TO: Nursing Superintendence (ACER)
	TO: Intoxcence office (ACER)				03		1/11 (Friday)		TO: Maintenance dept. (ACER)
	TO: Establishment section (ACER)				02 (Two)		1/11 (Friday)		TO: X-ray department (ACER)
	TO: Account section (ACER)				03		1/11 (Friday)		TO: Hospital store (ACER)

BGS GIMS HOSPITAL
67, BGS Heat
& Uttarahalli R.
Bengaluru - 560 007

GPS Map Camera



Bengaluru, Karnataka, India
 WF2W+2JM, Kodipalya, Bengaluru, Karnataka
 560060, India
 Lat 12.900113°
 Long 77.496779°
 07/10/22 12:49 PM GMT +05:30

ASIANET GROUPS **SERVICE REPORT / GATE PASS** Ph : 080-23186882
ASIANET GROUPS 9844443341
 7204020444
 SERVICE PROVIDED THROUGH OUT BANGALORE
 Website : www.asianetbangalore.com, Email : enquiry@asianetbangalore.com
 For any Clarification Please send to this No.: 93414 07015

CLIENT FEED BACK NAME :
 Excellent Very Good
 Good Average

Sl. No.: **1494**
 Working Date: **19/10/2022**

Ms.: **B.G.S. GIMS. G.M.S. Hostels. U.G. & P.G.**
 Address: Ph:

No. of Sump Tank	No. of RCC & PVC Tank	STP Lorry & Tractor No. Loads
1. Tanks. 5000X6 Nos	1.	Company Seal MAINTENANCE ENGINEER BGS GIMS & HOSPITAL Kengeri, Bangalore-560 060 <i>Shiva Kumar</i> 20/10/2022
2. Tank. 1000X1 Nos	2.	
3.	3.	
4.	4.	
5.	5.	

Worker's 1. Name: 2. 3. 4. Start Time : Close Time :
 Work Complete : Yes No

Sup Name : Checked by : Manager/Supervisor
 Security Name : Name: **Jagadeesh Yallosi**
 Signature : Signature: *[Signature]* Working Vehicle Nos. :
 Mobile : Mobile: **8660459900** Van & Lorry

ASIANET GROUPS **SERVICE REPORT / GATE PASS** Ph : 080-23186882
ASIANET GROUPS 9844443341
 7204020444
 SERVICE PROVIDED THROUGH OUT BANGALORE
 Website : www.asianetbangalore.com, Email : enquiry@asianetbangalore.com
 For any Clarification Please send to this No.: 93414 07015

CLIENT FEED BACK NAME :
 Excellent Very Good
 Good Average



Sl. No.: **1495**
 Working Date :



Ms.: **GIMS. Boys Hostel & Sump**
 Address: Ph:





No. of Sump Tank	No. of RCC & PVC Tank	STP Lorry & Tractor No. Loads
TANKS. 5000X2	1.	Company Seal MAINTENANCE ENGINEER BGS GIMS & HOSPITAL Kengeri, Bangalore-560 060 <i>Shiva Kumar</i> 20/10/2022
Sump. 6000X1 liters.	3.	
	4.	
	5.	





Worker's 1. Name: 2. 3. 4. Start Time : Close Time :
 Work Complete : Yes No




Sup Name : Checked by : Manager/Supervisor
 Security Name : Name: **Jagadeesh Yallosi**
 Signature : Signature: *[Signature]* Working Vehicle Nos. :
 Mobile : Mobile: **8660459900** Van & Lorry




 SERVICE REPORT / GATE PASS Ph : 080-23186882 ASIANET GROUPS 9844443341 SERVICE PROVIDED THROUGH OUT BANGALORE 7204020444 Website : www.asianetbangalore.com, Email : enquiry@asianetbangalore.com For any Clarification Please send to this No.: 93414 07015		CLIENT FEED BACK NAME : Excellent <input type="checkbox"/> Very Good <input type="checkbox"/> Good <input type="checkbox"/> Average <input type="checkbox"/>	
Ms. B.G.S. GIMS Hospital Address: Ph:		Sl. No.: 1498 Working Date : 20/10/2022	
No. of Sump Tank	No. of RCC & PVC Tank	STP Lorry & Tractor No. Loads	
1. SUMP 25000 X 1 2. TANKS, 5000 X 2 3. TANKS, 2000 X 4 4. 5.	1. 2. 3. 4. 5.	Company Seal  MAINTENANCE ENGINEER BGS GIMS & HOSPITAL Kengeri, Bangalore-560 060	
Worker's 1. Name : 2. 3. 4.	3. 4.	Start Time : Close Time : Work Complete : Yes <input type="checkbox"/> No <input type="checkbox"/>	
Sup Name : Security Name : Signature : Mobile :	Checked by : Manager/Supervisor Name : Jagadeb Yalloji Signature : Mobile : 8660459900	Working Vehicle Nos. : Van & Lorry	1. 2. 3. 4.

 SERVICE REPORT / GATE PASS Ph : 080-23186882 ASIANET GROUPS 9844443341 SERVICE PROVIDED THROUGH OUT BANGALORE 7204020444 Website : www.asianetbangalore.com, Email : enquiry@asianetbangalore.com For any Clarification Please send to this No.: 93414 07015		CLIENT FEED BACK NAME : Excellent <input type="checkbox"/> Very Good <input checked="" type="checkbox"/> Good <input type="checkbox"/> Average <input type="checkbox"/>	
Ms. B.G.S. GIMS Hospital ANNEX-2 Address: Ph:		Sl. No.: 1499 Working Date : 20/10/2022	
No. of Sump Tank	No. of RCC & PVC Tank	STP Lorry & Tractor No. Loads	
1. TANKS, 5000 X 2 2. TANKS, 3000 X 2 3. TANK 2000 X 1 4. 5.	1. 2. 3. 4. 5.	Company Seal  MAINTENANCE ENGINEER BGS GIMS & HOSPITAL Kengeri, Bangalore-560 060	
Worker's 1. Name : 2. 3. 4.	3. 4.	Start Time : Close Time : Work Complete : Yes <input type="checkbox"/> No <input type="checkbox"/>	
Sup Name : Security Name : Signature : Mobile :	Checked by : Manager/Supervisor Name : Jagadeb Yalloji Signature : Mobile : 8660459900	Working Vehicle Nos. : Van & Lorry	1. 2. 3. 4.

 SERVICE REPORT / GATE PASS Ph : 080-23186882 ASIANET GROUPS 9844443341 7204020444 SERVICE PROVIDED THROUGH OUT BANGALORE Website : www.asianetbangalore.com, Email : enquiry@asianetbangalore.com For any Clarification Please send to this No.: ☎ : 93414 07015		CLIENT FEED BACK NAME : Excellent <input type="checkbox"/> Very Good <input type="checkbox"/> Good <input type="checkbox"/> Average <input type="checkbox"/>
Ms.: <u>B.G.S. G.I.M.S. College</u> Address: Ph:		Sl. No.: 1497 Working Date : <u>20/10/2022</u>
No. of Sump Tank 1. <u>Tank 2000x1</u> 2. 3. 4. 5.	No. of RCC & PVC Tank 1. 2. 3. 4. 5.	STP Lorry & Tractor No. Loads Company Seal  MAINTENANCE ENGINEER BGS GIMS & HOSPITAL Kengeri, Bangalore-560 060 Start Time : Close Time : Work Complete : Yes <input type="checkbox"/> No <input type="checkbox"/>
Worker's 1. Name : 2. 3. 4.	Checked by : Manager/Supervisor Name : <u>Jogatep Yallosi</u> Signature :  Mobile : <u>8660459900</u>	Working Vehicle Nos. : Van & Lorry 1. 2. 3. 4.
Sup Name : Security Name : Signature : Mobile :	Checked by : Manager/Supervisor Name : <u>Jogatep Yallosi</u> Signature :  Mobile : <u>8660459900</u>	Working Vehicle Nos. : Van & Lorry 1. 2. 3. 4.

 SERVICE REPORT / GATE PASS Ph : 080-23186882 ASIANET GROUPS 9844443341 7204020444 SERVICE PROVIDED THROUGH OUT BANGALORE Website : www.asianetbangalore.com, Email : enquiry@asianetbangalore.com For any Clarification Please send to this No.: ☎ : 93414 07015		CLIENT FEED BACK NAME : Excellent <input type="checkbox"/> Very Good <input type="checkbox"/> Good <input type="checkbox"/> Average <input type="checkbox"/>
Ms.: <u>B.G.S. G.I.M.S. Residents Hostel</u> Address: Ph:		Sl. No.: 1500 Working Date : <u>20/10/2022</u>
No. of Sump Tank 1. <u>TANKS, 5000x2</u> 2. 3. 4. 5.	No. of RCC & PVC Tank 1. 2. 3. 4. 5.	STP Lorry & Tractor No. Loads Company Seal  MAINTENANCE ENGINEER BGS GIMS & HOSPITAL Kengeri, Bangalore-560 060 Start Time : Close Time : Work Complete : Yes <input type="checkbox"/> No <input type="checkbox"/>
Worker's 1. Name : 2. 3. 4.	Checked by : Manager/Supervisor Name : <u>Jogatep Yallosi</u> Signature :  Mobile : <u>8660459900</u>	Working Vehicle Nos. : Van & Lorry 1. 2. 3. 4.
Sup Name : Security Name : Signature : Mobile :	Checked by : Manager/Supervisor Name : <u>Jogatep Yallosi</u> Signature :  Mobile : <u>8660459900</u>	Working Vehicle Nos. : Van & Lorry 1. 2. 3. 4.

 SERVICE REPORT / GATE PASS Ph : 080-23186882 ASIANET GROUPS 9844443341 SERVICE PROVIDED THROUGH OUT BANGALORE 7204020444 Website : www.asianetbangalore.com, Email : enquiry@asianetbangalore.com For any Clarification Please send to this No.: ☎ : 93414 07015		CLIENT FEED BACK NAME : Excellent <input type="checkbox"/> Very Good <input checked="" type="checkbox"/> Good <input type="checkbox"/> Average <input type="checkbox"/>	
Ms.: B.G.S. GIMS Teching E. Non Teching Address: Quaters Ph.....		Sl. No.: 1496 Working Date : 19/10/2022	
No. of Sump Tank 1. Tanks, 5000 X 2 2. 3. 4. 5.		No. of RCC & PVC Tank 1. 2. 3. 4. 5.	
Worker's 1. Name : 2. 3. 4.		STP Lorry & Tractor No. Loads Company Seal  MAINTENANCE ENGINEER BGS GIMS & HOSPITAL Kengeri, Bangalore-560 060 Start Time : Close Time : Work Complete : Yes <input type="checkbox"/> No <input type="checkbox"/>	
Sup Name : Security Name : Signature : Mobile :		Checked by : Manager/Supervisor Name : Jagadeep Yalloji Signature :  Mobile : 8660459900 Working Vehicle Nos. : Van & Lorry 1. 2. 3. 4.	

 SERVICE REPORT / GATE PASS Ph : 080-23186882 ASIANET GROUPS 9844443341 SERVICE PROVIDED THROUGH OUT BANGALORE 7204020444 Website : www.asianetbangalore.com, Email : enquiry@asianetbangalore.com For any Clarification Please send to this No.: ☎ : 93414 07015		CLIENT FEED BACK NAME : Excellent <input type="checkbox"/> Very Good <input type="checkbox"/> Good <input type="checkbox"/> Average <input type="checkbox"/>	
Ms.: B.G.S. GIMS CANARY BANK Quaters Address: Ph.....		Sl. No.: 3698 Working Date : 20/10/2022	
No. of Sump Tank 1. Sump - 6000 X 1 2. Tank - 2000 X 1 3. 4. 5.		No. of RCC & PVC Tank 1. 2. 3. 4. 5.	
Worker's 1. Name : 2. 3. 4.		STP Lorry & Tractor No. Loads Company Seal  MAINTENANCE ENGINEER BGS GIMS & HOSPITAL Kengeri, Bangalore-560 060 Start Time : Close Time : Work Complete : Yes <input type="checkbox"/> No <input type="checkbox"/>	
Sup Name : Security Name : Signature : Mobile :		Checked by : Manager/Supervisor Name : Jagadeep Yalloji Signature :  Mobile : 8660459900 Working Vehicle Nos. : Van & Lorry 1. 2. 3. 4.	

FIELD SERVICE REPORT



TANIESH TECHNOLOGIES

AN ISO 9001 : 2015 CERTIFIED COMPANY

48, Ground Floor, J C Industrial Area,
4th Cross, Saraswathi Road , Opp. Vinayaka
Temple, Bikasipura, Bangalore - 560 061.
Ph: 080-26660237 Fax: 080-26660287
Mobile : 96861 88924 / 98862 49093
E-mail: sales@tanieshtechnologies.com
suresh@tanieshtechnologies.com
Website : www.tanieshtechnologies.com

SERVICES AVAILABLE ACROSS THE COUNTRY

Customer Name & Address B.P.O. Pimp Medical Cottage Adirahalli main Road Examination Hall	Date: 20/10/2022	FSR No. 13403	
	Engineer Name: Abhishek		
	Equipment Details		
	Model: Inverter	Online UPS <input checked="" type="checkbox"/>	I & C <input type="checkbox"/> NEW <input type="checkbox"/>
	Capacity/VDC: 20/240	LI UPS <input type="checkbox"/>	Rental <input type="checkbox"/>
	Sl. No. FION2100619	PCU <input type="checkbox"/>	Standby <input checked="" type="checkbox"/>
	Battery Make: Exide	Battery <input checked="" type="checkbox"/> PM <input type="checkbox"/> AMC <input type="checkbox"/>	Replacement <input type="checkbox"/>
	Ah: 12v. 26AH	Stabilizer <input type="checkbox"/>	Wty <input type="checkbox"/>
Call Status: OK	Others <input type="checkbox"/>	Service <input type="checkbox"/> O/Wty <input type="checkbox"/>	

Nature of Work: Standby Battery installation

Nature of Problem:

- × Installed 6 Nos. Battery for Standby Purpose [Standby Battery. Provided second time]
- × Present UPS is working fine with good
- × All Batteries is weak. Need to Replace the old Batteries, [Batteries installed date 2019.]

Parameters			
Input Volt	R-N	236	Y-N 232
	B-N	235	N-E
Output Volt	R-N		Y-N
	B-N	230	N-E
Output Current	R	Y	B
Batt Volt	Rect Volt:	Batt Current	
	240v	270v	3.5A

Spares To be Billed : Yes No

Sl. No.	Spares Details	Qty.	Amount in

Service charges To be Billed : Yes No

Customer Comments :
1 No Battery found provided

Customer Signature & Seal

Engineer's Signature

FIELD SERVICE REPORT



TANIESH TECHNOLOGIES

TANIESH UPS & STABILIZER AN ISO 9001 : 2015 CERTIFIED COMPANY

48, Ground Floor, J C Industrial Area,
4th Cross, Saraswathi Road , Opp. Vinayaka
Temple, Bikasipura, Bangalore - 560 061.

Ph: 080-26660237 Fax: 080-26660287
Mobile : 96861 88924 / 98862 49093

E-mail: sales@tanieshtechnologies.com
suresh@tanieshtechnologies.com

Website : www.tanieshtechnologies.com

SERVICES AVAILABLE ACROSS THE COUNTRY

Customer Name & Address B.L.S. Kemp Medical College Kulturhalli main Road Kengeri Bangalore Centra. Lab.	Date: 20/10/2022	FSR No. 13410
	Engineer Name: <i>Abhinav</i>	
	Equipment Details	
	Model: <i>Abin's</i>	Online UPS <input checked="" type="checkbox"/> Rental <input type="checkbox"/>
	Capacity/VDC: 30/240	LI UPS <input type="checkbox"/> Standby <input checked="" type="checkbox"/>
	Sl. No: <i>TIN/230318</i>	PCU <input type="checkbox"/> Replacement <input type="checkbox"/>
	Battery Make: <i>Exide</i>	Battery <input checked="" type="checkbox"/> PM <input type="checkbox"/> AMC <input type="checkbox"/>
Ah: <i>42AH</i>	Stabilizer <input type="checkbox"/> Wty <input type="checkbox"/>	
Call Status: <i>-</i>	Others <input type="checkbox"/> Service <input type="checkbox"/> O/Wty <input type="checkbox"/>	

Nature of Work: *Stand by Battery installation*

Nature of Problem:

- x Installed 6 Nos Stand by Battery for UPS [stand by Batteries provided second time]*
- x Present UPS is working fine with led*
- x All Batteries is weak. Need to replace the old Batteries*

Parameters				
Input Volt	R-N	234	Y-N	236
	B-N	233	N-E	
Output Volt	R-N		Y-N	
	B-N	230	N-E	
Output Current	R	Y	B	
Batt Volt	Rect Volt:		Batt Current	
	240.v	270.v	4-6 A	

Spares To be Billed : Yes No

Sl. No.	Spares Details	Qty.	Amount in

Service charges To be Billed : Yes No

Customer Comments :

Abhinav
376055117
Customer Signature & Seal

Charges
Total

Abhinav
Engineer's Signature